



Monthly checks Customer Checks

Jan Feb Mar Apr May June July Aug Sep Oct Nov Dec

Fire Doors

Do doors on hold-open devices close on failure of power

supply and roller shutters provided for fire

compartmentalization work correctly on operation of the fire alarm system ?

Emergency Lighting

Do all luminaries and exit signs function correctly when flash tested for 5 minutes?

Fire Fighting Equipment

Is there still correct extinguisher coverage of fire risks?

Is the pressure in 'stored pressure' extinguishers correct?

Fire Safety Signage

Are all the necessary signs and notices in place?

Fire Log Book

Is the fire log book being updated?

Contact Us

operations@fstsystems.co.uk
0333 444 0032

DOWNLOAD MORE COPIES AT

WWW.FSTSYSTEMS.CO.UK

